IU2080NC

Modulo serie 2000, 1 uscita (Supervisionata)



General

Operation

The IU2080NC utilizes an advanced digital data communications protocol that ensures the integrity of the data communication with extensive error correction algorithms. It ensures system reliability with continuous supervision and monitoring of the output circuit for open or short circuit conditions, as well as monitoring of the input auxiliary power supply for low voltage or fault conditions. The output circuit supports a continuous or pulsing output that significantly simplifies meeting requirements for differentiation of audible alarms for different alarm circumstances.

Installation

The IU2080NC loop address is set with a simple decimal rotary dial and is non-volatile - the address is not lost in the event of a power outage. The module is simply connected to a compatible fire alarm panel via a two-wire device communication loop that carries both data and operating power to the module. The indicating circuit is powered via a auxiliary power supply.

Programmability

The operation of the IU2080NC is fully configurable from the CIE (control panel) allowing for powerful and extremely flexible output configuration capabilities.

IU2080NC

Modulo serie 2000, 1 uscita (Supervisionata)

Specifiche tecniche

General

Addressing method	Rotary switch

Electrical

Power supply type	24 VDC, Loop-Stromversorgung

Physical

Colour	Weiß
Mounting type	Oberflächenmontage
Material	Plastik

Environmental

Vandal proof	No
Environment	Drinnen

Regulatory

Compliancy	CE, REACH, RoHS 3, WEEE
Certification	CPR

In quanto azienda in continua innovazione, Kidde Global Solutions si riserva il diritto di modificare le specifiche del prodotto senza preavviso. Per avere informazioni sempre aggiornate, visita it.firesecurityproducts.com online o contatta il tuo riferimento commerciale.

Last updated on 12 November 2026 - 18:57